

CITY OF DANIA BEACH, FLORIDA



I.T. PARKER COMMUNITY CENTER HVAC REPLACEMENT

CITY INVITATION TO BID (“ITB.”) NO. 22-003

ADDENDUM

Prepared by:

City of Dania Beach, Florida
100 W. Dania Beach Boulevard
Dania Beach, Florida 33004

FEBRUARY 3, 2022

**CITY OF DANIA BEACH, FLORIDA
INVITATION TO BID FOR
“I.T. PARKER COMMUNITY CENTER
HVAC REPLACEMENT”
ITB 22-003**

TO ALL BIDDERS: PLEASE TAKE NOTE OF THE FOLLOWING REVISIONS, ADDITIONS, DELETIONS, CLARIFICATIONS, ETC. RELATIVE TO THE SOLICITATION, WHICH IN ACCORDANCE WITH THE CONTRACT DOCUMENTS SHALL BECOME A PART OF AND HAVE PRECEDENCE OVER ANYTHING SHOWN OR DESCRIBED OTHERWISE.

THE FOLLOWING MODIFICATIONS TO THE DOCUMENTS ARE MADE:

- 1. The bid specifications are revised from two (2) 15-ton condensing units to two (2) 12.5 ton condensing units.**
- 2. The bid form has been revised to reflect two (2) 12.5-ton condensing units and the addition of three (3) Honeywell T6 Pro Smart Thermostats. An updated bid form accompanies this addendum.**

City of Dania Beach

ITB 22-003: I.T. Parker Community Center HVAC Replacement

No.	Item	Quantity	Unit	Unit Price	Total
1	3.5 Ton Condensing Unit	1	EA		
2	3 Ton Condensing Unit	1	EA		
3	15 Ton Condensing Unit 12.5 Ton Condensing Unit	2	EA		
4	4 Ton Fan Coil Unit	2	EA		
5	8 kW Electric Heater	2	EA		
6	40 RU Air Handler Unit	1	EA		
7	60 hz Electric Heater	1	EA		
8	Honeywell T6 Pro Smart Thermostat	3	EA		
TOTAL COST					